

बिड दस्तावेज़ / Bid Document

| बिड विवरण/Bid Details | |
|---|--|
| बिड बंद होने की तारीख/समय /Bid End Date/Time | 01-07-2026 11:00:00 |
| बिड खुलने की तारीख/समय /Bid Opening Date/Time | 01-07-2026 11:30:00 |
| बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date) | 75 (Days) |
| मंत्रालय/राज्य का नाम/Ministry/State Name | Ministry Of Chemicals And Fertilizers |
| विभाग का नाम/Department Name | Department Of Fertilizers |
| संगठन का नाम/Organisation Name | Rashtriya Chemicals And Fertilizers Limited (rcf) |
| कार्यालय का नाम/Office Name | Rcf Ltd Thal Unit Alibag |
| शिकायत निवारण के संपर्क विवरण/ Contact details of Grievance redressal | anjali.bagde@rcf ltd.com |
| वस्तु श्रेणी /Item Category | Repair, Maintenance, and Installation of Plant/ Systems/Equipments (Version 2) - Industry Unit; Electrical System or Installation, LED FITTING REPLACEMENT JOB; Service Provider |
| अनुबंध अवधि /Contract Period | 1 Year(s) |
| एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover | No |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover | No |
| विक्रेता से मांगे गए दस्तावेज़/Document required from seller | Experience Criteria,Certificate (Requested in ATC),Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid? | No |

| बिड विवरण/Bid Details | |
|--|---|
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension | 3 |
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended | 7 |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count | 1 |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled | No |
| बिड का प्रकार/Type of Bid | Two Packet Bid |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation | 3 Days |
| Payment Timelines | Payments shall be made to the Seller within 30 days of issue of service delivery acceptance certificate (SDAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC) |
| मूल्यांकन पद्धति/Evaluation Method | Total value wise evaluation |
| मूल्य दर्शाने वाला वित्तीय दस्तावेज ब्रेकअप आवश्यक है / Financial Document Indicating Price Breakup Required | Yes |
| मध्यस्थता खंड/Arbitration Clause | No |
| सुलह खंड/Mediation Clause | No |

ईएमडी विवरण/EMD Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

ईपीबीजी विवरण /ePBG Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई अनुपालन/MII Compliance

| | |
|-------------------------------|-----|
| एमआईआई अनुपालन/MII Compliance | Yes |
|-------------------------------|-----|

एमएसई खरीद वरीयता/MSE Purchase Preference

| | |
|---|-----|
| एमएसई खरीद वरीयता/MSE Purchase Preference | Yes |
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% / Purchase Preference to MSE OEMs/ Service Provider available upto price within L1+X% | 15 |

ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for % (selected by Buyer) percentage of total quantity. The buyers are advised to refer the [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. If L-1 is not an MSE and MSE Service Provider (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band as defined in the relevant policy, then 100% order quantity will be awarded to such MSE bidder subject to acceptance of L1 bid price.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

एक्सेल में अपलोड किए जाने की आवश्यकता /Excel Upload Required :

Priced_Breakup - [1781689988.xlsx](#)

अतिरिक्त योग्यता /आवश्यक डेटा/Additional Qualification/Data Required

Buyer to mention scope of work:[1781689998.pdf](#)

Terms and Conditions/ Deductions etc to be mentioned by Buyer as per their requirement:[1781690007.pdf](#)

Any other details to be mentioned by buyer for repair work:[1781690012.pdf](#)

Any other details to be mentioned by buyer for repair work:[1781690017.pdf](#)

Repair, Maintenance, And Installation Of Plant/ Systems/Equipments (Version 2) -

**Industry Unit; Electrical System Or Installation, LED FITTING REPLACEMENT JOB;
Service Provider (1)**

तकनीकी विशिष्टियाँ /Technical Specifications

| विवरण/ Specification | मूल्य/ Values |
|---|---|
| कोर / Core | |
| Type of Premise | Industry Unit |
| Type of Item/Product/System to be repaired or Installed | Electrical System or Installation , LED FITTING REPLACEMENT JOB |
| Consumables to be provided by | Service Provider |
| Spare parts to be provided by | Service Provider |
| एडऑन /Addon(s) | |

क्रेता द्वारा निर्धारित न्यूनतम मूल्य/Minimum Floor Price defined by Buyer

| | |
|--|----|
| क्रेता द्वारा निर्धारित न्यूनतम मूल्य/Minimum Floor Price defined by Buyer | No |
|--|----|

अतिरिक्त विशिष्टि दस्तावेज़ /Additional Specification Documents

प्रेषिती/रिपोर्टिंग अधिकारी /Consignees/Reporting Officer and Quantity

| क्र.सं./S.N o. | प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | Quantity | अतिरिक्त आवश्यकता /Additional Requirement |
|-------------------|--|--|-------------------------------|---|
| 1 | Prashant Kumar | 402208,RCF LTD, THAL UNIT, TAL - ALIBAG, RAIGAD | Project / Lumpsum Based | <ul style="list-style-type: none">Estimated Cost of Spare/Consumables/Items on Reimbursement basis in Rs (please input 0 if not applicable) : 0 |

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

2. Buyer Added Bid Specific Scope Of Work(SOW)

Text Clause(s)

SCOPE OF WORK

A1. GENERAL:

It is planned to replace faulty /out of order (Due to aging/Faulty driver, etc.) light fittings in various plants sections in Ammonia Plant, RCF Thal.

The present faulty light fittings will be removed and new LED fittings to be installed in their place. The location may be modified to get good illumination effect. Different types of fitting are to be installed at various heights from ground.

1. The job is to be done at Ammonia plants, RCF Thal.
2. Party should take electrical work permit wherever required before starting the job and utmost care while carrying out the job.
3. Party shall arrange to install new LED fittings. Job includes removal of Old fittings, new fitting installation, if required replacement of fitting clamps, poles, Replacement of cable, re-termination of cable, etc.
4. The job involves Installation, Testing and Commissioning of lighting fixtures with their parts and accessories, glanding of cables, Internal & External reflectors, canopy etc.
5. Faulty LED fittings (45W/120W) shall be replaced with new LED fittings provided by RCF. Mounting may be different for new fittings. Suitable Mounting/Fixing arrangement for new fittings in the scope of bidder.
6. Job may be in plant area on platforms at different heights (3 to 90 Meter) from ground, pole fittings, staircases, On compressor house top structure which is accessed via EOT crane, on regenerator, absorber and LPGV towers having height up to 90meter from ground, etc.
7. Party shall visit the site to assess feasibility of location, quantum of the job and quote accordingly.
8. Party should arrange for material handling, transportation from owners store to erection site, unpacking, inspection; checking of internal wiring.
9. Party has to carry out required modifications for fixing the new LED fittings.
10. Party shall arrange any hardware (ss) for installation of the fittings in addition to which supplied by the manufacturer of LED fittings.
11. At some places supply cable, junction box is to be replaced.
12. The supply shall be isolated before starting the job.
13. Testing of the fittings shall be done before handing over the job.
14. Removed materials will be retained by RCF.
15. Proper housekeeping shall be done after completion of job.
16. Job may be carried out in two or more phases depending on site clearance.
17. Party shall arrange to shift all material to actual work site from RCF central store.
18. Any other job required for successful installation of the fittings is in the scope of

bidder.

19. Party has to bring all required tools and tackles such as welding machine, drill machine, taps, cutting machine, ladders and other necessary tools along with required manpower (skilled with supervisor license compulsory and unskilled) for the job. The manpower shall have work experience in similar installation.

A2. Procedure for 45W LED fittings replacement having height up to 3 Mtr from ground or fixed working platform-

1. Isolate supply of area lighting or fitting from Main incoming feeder.
2. Removal of wires termination / Disconnection of wire joints of old fitting.
3. Dismounting of old fitting.
4. Handing over the old fitting to respective plant Elect dept.
5. Collecting new tested ok LED fitting from respective plant Elect dept.
6. Mounting of new LED type fitting.
7. Connection of 3core X 2.5 Sq.mm termination/jointing of wires to new fitting with inline glass fuse holder and 1Amp glass fuse to isolate individual fitting in case of fault. Required glass fuse and glass fuse holder is in scope of bidder.
8. Replacement of 3core X 2.5 Sq.mm. armoured service cable from fitting to Junction box if required. Re-glanding and clamping of cables to be done if required. Required cable and cable gland is in scope of RCF, required clamping material is in scope of Bidder.
9. Scope also included replacement of damaged Junction box if required, re-glanding and re-termination of all incoming and outgoing cables of junction box. Required Junction box (4Way JB), cable glands is in RCF scope. Required mounting arrangement of junction box is in scope of bidder.
10. Insulating the wire joint with electrical insulation tape.
11. Closing Junction box properly.
12. Checked Fittings after installation and rectify the problem if any.

A3. Procedure for 120W LED fittings replacement having height up to and above 3 Mtr from ground or fixed working platform

1. Isolate supply of area lighting or fitting from Main incoming feeder.
2. Fittings are made accessible using EOT crane or by using Articulated Boom lifts vehicle or by using scaffolding. EOT, Articulated Boom lifts vehicle and scaffolding is in scope of RCF
3. Removal of wires termination / Disconnection of wire joints of old fitting.
4. Dismounting of old fitting.
5. Handing over the old fitting to respective plant Elect dept.
6. Collecting new tested ok LED fitting from respective plant Elect dept.
7. Mounting of new LED type fitting.

8. Connection of 3core X 2.5 Sq.mm termination/jointing of wires to new fitting with inline glass fuse holder and 1Amp glass fuse to isolate individual fitting in case of fault. Required glass fuse and glass fuse holder is in scope of bidder.
9. Replacement of 3core X 2.5 Sq.mm. armoured service cable from fitting to Junction box if required. Re-glanding and clamping of cables to be done if required. Required cable and cable gland is in scope of RCF, required clamping material is in scope of Bidder.
10. Scope also included replacement of damaged Junction box if required, re-glanding and re-termination of all incoming and outgoing cables of junction box. Required Junction box (4Way JB), cable glands is in RCF scope. Required mounting arrangement of junction box is in scope of bidder.
11. Insulating the wire joint with electrical insulation tape.
12. Closing Junction box properly.
13. Checked Fittings after installation and rectify the problem if any.

A4. Procedure for 45W LED fittings replacement on vertical vessels having height above 20 meter-

1. Existing fittings are installed at Each landing platform of Vertical vessels (Regenerator, Absorber, LPGV, etc) having approximate total height from 20Mtr to 90Mtr from ground.
2. Isolate supply of area lighting or fitting from Main incoming feeder.
3. Fittings are accessible with fixed platform on each landing of Cage Monkey Ladders.
4. Removal of wires termination / Disconnection of wire joints of old fitting.
5. Dismounting of old fitting.
6. Handing over the old fitting to respective plant Elect dept.
7. Collecting new tested ok LED fitting from respective plant Elect dept.
8. Mounting of new LED type fitting.
9. Connection of 3core X 2.5 Sq.mm termination/jointing of wires to new fitting with inline glass fuse holder and 1Amp glass fuse to isolate individual fitting in case of fault. Required glass fuse and glass fuse holder is in scope of bidder.
10. Replacement of 3core or 4 core or 5core X 2.5 Sq.mm. armoured service cable from fitting to Junction box and between two junction box if required. Re-glanding and clamping of cables to be done if required. Required cable and cable gland is in scope of RCF, required clamping material is in scope of Bidder.
11. Scope also included replacement of damaged Junction box if required, re-glanding and re-termination of all incoming and outgoing cables of junction box. Required Junction box (4Way JB), cable glands is in RCF scope. Required mounting arrangement of junction box is in scope of bidder.
12. Insulating the wire joint with electrical insulation tape.
13. Closing Junction box properly.

14. Checked Fittings after installation and rectify the problem if any.

A5. Scope of RCF -

1. Power cable 5Core or 4core or 3core X 2.5 Sq.mm. service cable, Junction box, LED fittings, insulation tape, glands will be provided by RCF.
2. One Box type, foldable, four wheel portable street light ladder will be provided by RCF. Party has to carry the ladder from elect. Workshop to actual site by manually pushing it. After completion of job party will again carry back the ladder to Elect. Workshop in condition as it was. Repair of damage, if any, to the ladder during the job will be in the scope of the party.
3. Articulated Boom lifts vehicle and scaffolding if required will be provided by RCF for height above 6mtr.
4. Medical help provided by RCF shall be limited to first aid

A5. Scope of Bidder -

1. Required Skilled (skilled with supervisor license) and unskilled manpower.
2. Required 1Amp Glass fuse and inline glass fuse holder.
3. Cable clamping material
4. All required tools, welding machine, drill machine, taps, cutting machine, ladders, etc.
5. Proper personal safety equipment like Safety Helmet, Safety goggle, Safety belt, Safety Shoes, etc.

NOTE -

1. Contractor will mobilize his manpower on the instruction of RCF engineer in charge during the tenure of contract.
2. Workmen compensation insurance shall be taken for heights more than 3 meter s.
3. 120W LED fittings replacement Job is required to be done on ten meter height by standing on EOT crane cross travel trolley under supervision of RCF Electrical engineer. Street light replacement job is to be done with the help of portable box type ladder or Articulated Boom lifts vehicle. Proper personal safety equipment like Safety Helmet, Safety goggle, Safety belt, Safety Shoes and insulated hand tools must be used. **Proper insurance for heightened job is essential** (height more than 3 mtr)
4. The contractor shall be solely responsible for any damage/s to the machinery, equipment and property of RCF due to negligence of his staff or defective tools and tackles while installation & commissioning job.
5. Payment will be made as per quantity executed.
6. Cost of Required glass fuse and inline fuse holder, cost of required manpower for fitting replacement, required hardware for installation of fittings shall be included in the rate of fitting replacement.
7. Cost of cable clamping material, hardware, cost of required manpower for cable

replacement shall be included in the rate of cable replacement.

8. Cable should be properly dressed and well clamped.
9. Cost of material required for junction box (4Way JB) mounting, hardware, cost of required manpower for JB replacement shall be included in the rate of JB replacement.
10. Height pass will be conducted in RCF safety department.
11. If any personnel fails in height pass or unfit in medical checkup or technically non-performing, bidder has to arrange for replacement for the same.

The quantity mentioned in schedule of rates is tentative, may vary as per actual requirement

A6 Tenure of the contract: The contract shall be valid for a period of ONE year.

NOTE -

- i) The quantity mentioned in schedule of rates is tentative, may vary as per actual requirement.
- ii) Payment will be made as per quantity executed.
- iii) Rate is basic, GST will be paid extra.

__**

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.

10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

This Bid is governed by the [सामान्य नियम और शर्तें/General Terms and Conditions](#), conditions stipulated in Bid and [Service Level Agreement](#) specific to this Service as provided in the Marketplace. However in case if any condition specified in सामान्य नियम और शर्तें/General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement, then it will over ride the conditions in the General Terms and Conditions.

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---